

Exova Warringtonfire
Holmesfield Road
Warrington
WA1 2DS
United Kingdom

T : +44 (0) 1925 655 116
F : +44 (0) 1925 655 419
E : warrington@exova.com
W: www.exova.com



Testing. Advising. Assuring.

Title:

The Fire Resistance
Performance Of Timber Or
Mineral Composite Based
Insulated Doorsets When
Fitted With D & E Architectural
Hardware Spring Hinges

Report No:

331560/C

Prepared for:

**D&E Architectural Hardware
Limited**

17 Royce Road,
Carr Road Industrial Estate
Peterborough,
Cambridgeshire
PE1 5YB

Date:

24th January 2014

TABLE OF CONTENTS

SECTION	PAGE
Executive Summary.....	3
Introduction	4
Assumptions	4
Proposals	4
Basic Test Evidence	5
Assessed Performance	5
Conclusions	7
Validity	7
Summary of Primary Supporting Data	8
Declaration by D & E Architectural Hardware Limited.....	9
Signatories	10
Annex A – Approved Hardware	11

Executive Summary

Objective	This report presents an appraisal of the fire resistance performance of timber or mineral composite based doorsets when fitted with the referenced spring hinges, if tested in accordance with BS EN 1634-1 or BS 476: Part 22: 1987.
Report Sponsor	D&E Architectural Hardware Limited
Address	17 Royce Road, Carr Road Industrial Estate, Peterborough, Cambridgeshire, PE1 5YB.
Summary of Conclusions	Should the recommendations given in this report be followed, it can be concluded that the spring hinges listed within the tables included in Annex A of this report may be fitted to previously tested or assessed (by Exova Warringtonfire) insulated doorsets, to provide 60 minutes integrity performance, if tested in accordance with BS EN 1634-1 or BS 476: Part 22: 1987.
Valid until	1 st February 2019

This report may only be reproduced in full. Extracts or abridgements of reports shall not be published without permission of Exova Warringtonfire.

Introduction

This report presents an appraisal of the fire resistance performance of double-acting insulated doorsets when fitted with the referenced double action spring hinges. The doorset, onto which the proposed hardware is to be fitted, may be of single-leaf or double-leaf configuration.

The proposed doorsets are required to provide a fire resistance performance of 60 minutes integrity, with respect to BS EN 1634-1 or BS 476: Part 22: 1987

FTSG

The data referred to in the supporting data section has been considered for the purpose of this appraisal which has been prepared in accordance with the Fire Test Study Group Resolution No. 82: 2001.

Assumptions

Doorset details

It is assumed that the hardware will be fitted to an insulated doorset (timber or mineral composite based) which has also been previously shown to be capable of providing the required fire resistance performance when tested in accordance with BS EN 1634-1 or BS 476: Part 22: 1987 in the proposed configuration i.e. single-leaf or double-leaf. Additionally the spring hinges shall only be fitted to doorsets that have been previously proven in double-action configuration. The critical aspects of the door construction are detailed later in this report.

Supporting wall

It is also assumed that the construction of the wall, which supports the proposed doorsets, will have been the subject of a separate test and the performance of the wall is such that it will not influence the performance of the doorset for the required period.

Clearance gaps

Door leaf to frame clearance gaps can have a significant effect on the overall fire performance of a doorset. It is therefore assumed that the leaf to leaf and leaf to frame clearance gaps will not exceed those measured for the relevant fire tested doorset. In addition, it is assumed that the door leaves will be in the closed position and, where appropriate, latched position.

Proposals

It is proposed that the hardware may be fitted into a previously tested (in accordance with BS EN 1634-1 or BS 476: Part 22: 1987) insulated (timber or mineral composite) doorset which has been shown to be capable of providing 60 minutes integrity and insulation in the same configuration as that proposed i.e. single-leaf or double-leaf.

Basic Test Evidence

WF Test Report No. 324188

The test referenced WF Test Report No. 324188 included two double-acting, single-leaf timber based doorsets referenced as Doorset A and Doorset B. Only the information relating to Doorset B is relevant to this appraisal.

Doorset B had overall dimensions of 2018 mm high by 1032 mm wide and incorporated a door leaf of overall dimensions 1975 mm high by 930 mm wide by 54 mm thick. The door leaf was hung within a hardwood door frame on two double action spring hinges referenced 'DELDA08 EI60'. The doorset also incorporated two door viewers.

The doorset achieved an integrity performance of 61 minutes.

Assessed Performance

General

It is proposed that previously fire tested (or assessed by Exova Warringtonfire) timber or mineral composite based insulated doorsets may be fitted with the spring hinges without detracting from the performance of the doorset.

The performances of Doorset B during the test referenced WF No. 324188 is cited to display the ability of the spring hinges to contribute towards the required fire resistance performance.

The test included an insulated (timber based) door leaf and upon examination of the test report it can be seen that there were no modes of integrity failure, which were either attributable to or co-incident with the performance or presence of the proposed hinges within the 60 minute target performance.

The hinges referenced 'DELDA08 EI60' fitted to the 60 minute doorset construction of Doorset B were a double-action spring hinge of mild steel construction. Review of the observations contained in the test report show that the hinges contributed positively to the performance of the doorset for far in excess of the 60 minute performance required from the doorset.

Initial integrity failure of the doorset occurred after 61 minutes, but this mode of failure was not associated with the performance or presence of the hinges.

The observations shown that the test continued beyond the initial failure of the doorset until 66 minutes at which time the test was terminated without any instance of integrity failure attributable to the performance of the hinges.

It is therefore reasonable to consider that, based on the performance of the DELDA08 EI60 hinges during the test, a high level of confidence can be taken in the proposal that the hinges may be fitted to other, previously proven, timber or mineral composite based insulated doorsets whilst continuing to positively contribute to the performance of the doorset for the required 60 minute performance.

The tested doorset assembly included two hinges and each hinge was provided with intumescent protection kit in the form of a 2 mm thickness of sheet material fitted behind each blade for the full length of the hinge blade in contact with the door leaf and door frame.

It is therefore a requirement of this appraisal that a minimum of two hinges be fitted to a door leaf and that the same intumescent protection kit is provided as part of their installation.

Alternative hinge references

The tested hinges are marketed under various different references as are their associated intumescent protection kits. In all instances both the hinges and the intumescent kit are identical to those included in the test. Details of the various alternative references and approved finishes for the hinges are given in the tables in Annex A at the end of this report.

Proposed Doorsets

As stated in this report, the doorset, in the required configuration, will be previously tested (or assessed by Exova Warringtonfire) and its performance is therefore not in doubt.

To enable the use of the spring hinges on a range of doorsets, it is necessary to address the available information on the proposed doorset. As this appraisal is intended to be used on a general basis and not restricted to any particular manufacture of fire resisting doorset, the following points are given to enable the hardware to be used safely:

The critical aspects of the doorset construction in terms of the performance of the proposed hinges are considered to be the material of the door frame, the leaf to frame clearance gaps and the lipping material to the door leaf. Attention should be paid to these details and these should not be amended from that previously fire tested. Where this information is not known the following minimum specification will be followed:

- a) The doorset shall carry valid certification or the doorset, including the door frame and associated hardware should have achieved 60 minutes integrity (as appropriate), when tested by a UKAS approved laboratory (or assessed by Exova Warringtonfire) to BS EN 1634-1 or BS 476: Part 22: 1987.
- b) If the proposed doorset is to be used in double-leaf configuration the test or assessment evidence should be applicable to double-leaf configurations.
- c) Door leaves for 60 minute applications shall have minimum thicknesses of 54 mm and shall be fitted with hardwood timber lippings having a minimum thickness of 8 mm and a minimum density of 650 kg/m³.
- d) Door frames for 60 minute doorsets shall be hardwood timber with a minimum density of 650 kg/m³.
- e) Where the proposed double-action hinges are to be installed, the test or assessment evidence for the proposed doorset should be applicable to double-action configurations.

Conclusions

Timber or mineral composite based doorsets that have previously been successfully fire tested by a UKAS accredited laboratory (or assessed by Exova Warringtonfire) which have achieved 60 minutes integrity as discussed in this report, may be fitted with the spring hinges listed in Annex A, without detracting from the overall performance of the doorset.

Validity

This assessment is issued on the basis of test data and information available at the time of issue. If contradictory evidence becomes available to warringtonfire the assessment will be unconditionally withdrawn and D & E Architectural Hardware Limited will be notified in writing. Similarly the assessment is invalidated if the assessed construction is subsequently tested because actual test data is deemed to take precedence over an expressed opinion. The assessment is valid initially for a period of five years i.e. until 1st February 2019, after which time it is recommended that it be returned for re-appraisal.

The appraisal is only valid provided that no other modifications are made to the tested construction other than those described in this report.

Summary of Primary Supporting Data

WF Test Report No. 324188

Test report relating to the performance of two fully insulated, double-acting, single-leaf, timber doorsets incorporating various items of building hardware, when subjected to a test in accordance with BS EN 1634-1: 2008 to determine their fire resistance performance.

For the purposes of the test, the doorsets were referenced Doorset A and Doorset B. Only details of the relevant doorset, Doorset B are included.

Doorset B had overall dimensions of 2018 mm high by 1032 mm wide and incorporated a door leaf of overall dimensions 1975 mm high by 930 mm wide by 54 mm thick. The door leaf was hung within a hardwood door frame on two Double Action Spring Hinges referenced 'DELDA08 EI60'. The door leaf comprised a three layer particle board Halspan core, timber stiles and rails and hardwood lippings to the vertical edges. The doorset also incorporated two door viewers.

The specimen satisfied the test requirements for the following periods:

		Doorset B
Integrity	Sustained Flames	61 minutes
	Gap Gauge	66 minutes*
	Cotton Pad	61 minutes
Insulation		61 minutes

* The test duration. The test was discontinued after a period of 66 minutes.

Test date : 9th January 2013

Test sponsor : D & E Architectural Hardware Limited

Declaration by D & E Architectural Hardware Limited

We the undersigned confirm that we have read and complied with the obligations placed on us by the UK Fire Test Study Group Resolution No. 82: 2001.

We confirm that the component or element of structure, which is the subject of this assessment, has not to our knowledge been subjected to a fire test to the Standard against which the assessment is being made.

We agree to withdraw this assessment from circulation should the component or element of structure be the subject of a fire test to the Standard against which this assessment is being made.

We are not aware of any information that could adversely affect the conclusions of this assessment.

If we subsequently become aware of any such information we agree to cease using the assessment and ask Exova Warringtonfire to withdraw the assessment.

Signed:

.....
For and on behalf of:


.....

Signatories



Responsible Officer

D. Forshaw* - Principal Certification Engineer



Approved

A. Kearns* - Technical Manager

* For and on behalf of Exova Warringtonfire.

Report Issued: 24th January 2014

The assessment report is not valid unless it incorporates the declaration duly signed by the applicant.

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The pdf copy supplied is the sole authentic version of this document. All pdf versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.

Annex A – Approved Hardware

Alternative References for Spring Hinges for 60 minute applications			
DELDA08	LDA08	No. 42	128101
DEGRDA08	GRLDA08		GR128101

Alternative References for Intumescent Kit for Spring Hinges for 60 minute applications					
DEIKLDA08/FD60	DEIKLDA08/FD60 KIT	DEIKLDA08/EI60	DEIKLDA08/EI60 KIT	DELDA08/FD60 KIT	DELDA08/EI60 KIT
IKLDA08/FD60	IKLDA08/FD60 KIT	IKLDA08/EI60	IKLDA08/EI60 KIT	LDA08/FD60 KIT	LDA08/EI60 KIT
DEIKGRDA08/FD60	DEIKGRDA08/FD60 KIT	DEIKGRDA08/EI60	DEIKGRDA08/EI60 KIT	DEGRDA08/FD60 KIT	DEGRDA08/EI60 KIT
IKGRDA08/FD60	IKGRDA08/FD60 KIT	IKGRDA08/EI60	IKGRDA08/EI60 KIT	GRLDA08/FD60 KIT	GRLDA08/EI60 KIT
DEIK128101 FD60	DEIK128101 FD60 KIT	DEIK128101 EI60	DEIK128101 EI60 KIT	DE128101 FD60 KIT	DE128101 EI60 KIT
IK128101 FD60	IK128101 FD60 KIT	IK128101 EI60	IK128101 EI60 KIT	128101 FD60 KIT	128101 EI60 KIT
DEIKGR128101/FD60	DEIKGR128101/FD60 KIT	DEIKGR128101/EI60	DEIKGR128101/EI60 KIT	DEGR128101/FD60 KIT	DEGR128101/EI60 KIT
IKGR128101/FD60	IKGR128101/FD60 KIT	IKGR128101/EI60	IKGR128101/EI60 KIT	GR128101/FD60 KIT	GR128101/EI60 KIT
DEIK42/FD60	DEIK42/FD60 KIT	DEIK42/EI60	DEIK42/EI60 KIT	DE42/FD60 KIT	DE42/EI60 KIT
IK42/FD60	IK42/FD60 KIT	IK42/EI60	IK42/EI60 KIT	42/FD60 KIT	42/EI60 KIT

Alternative References for Combined Spring Hinges/Intumescent Kit for 60 minute applications			
DELDA08 FD60	LDA08 FD60	No. 42 FD60	128101 FD60
DELDA08 EI60	LDA08 EI60	No. 42 EI60	128101 EI60
DEGRDA08 FD60	GRLDA08 FD60		GR128101 FD60
DEGRDA08 EI60	GRLDA08 EI60		GR128101 EI60

All part numbers listed above refer solely to the silver finish.

Finishes Available:

- Black
- Brown
- Gold
- RAL colour
- Silver
- White
- Stainless steel
- Bronze
- Brass plated
- Chrome plated
- Galvanised
- Zinc plated
- Natural steel